



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Kalimpong**  
**West Bengal Fire & Emergency Services**  
**Station Feeder Road, P.O & P.S Siliguri,**  
**District: Darjeeling, Pin - 734005**

Memo no.:IND/WB/FES/20192020/61861

Date: 30-11-2023

**From:**

**Divisional Fire Officer, Kalimpong**  
**West Bengal Fire & Emergency Services**

**To: THE PRINCIPAL KAMAL JYOTI VIDYA PEETH HIGH SCHOOL**  
**EAST MAIN ROAD KALIMPONG 734301**

**Sub: Sub:Renewal of Fire Safety Certificate of Existing construction of G+1 storied Institutional Building under group of Institutional of The Principal Kamal Jyoti Vidyapeeth High School at the Premises no East Main Road, KALIMPONG 734301**

This is in reference to your application no. 0125191239200022 dated 22-11-2023 regarding the Sub:Renewal of Fire Safety Certificate of Existing construction of G+1 storied Institutional Building under group of Institutional of The Principal Kamal Jyoti Vidyapeeth High School at the Premises no East Main Road, KALIMPONG 734301

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

This is in reference to your application no. 0125191239200022 dated 22/11/2023 regarding the Renewal of Fire Safety Recommendation of Existing construction of G+1 storied Institutional Building under group of Institutional of The Principal, Kamal Jyoti Vidyapeeth High School at the Premises no East Main Road, KALIMPONG 734301

The performance of the fire fighting system as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the renewal of fire safety certificate for occupancy of the aforesaid building.

However to up keep the fire safety measure of the aforesaid building the following safety measures need to be

incorporated/maintained.

Subject to fulfilment of the following conditions:

1. Good housekeeping to be maintained both inside as well as outside the building
2. Floor numbers as well as directional signs of escape routes to be prominently displayed.
3. Fire notice for evacuation and fire fighting to be prepared to display at vulnerable places in the building.
4. The occupants employees and security staff to be made well conversant about the installed fire safety and protection measures for their use in exigencies
- 5 Mock practice and fire evacuation drills to be organised for regular periodical performance in accordance to the National Building Code Part IV
- 6 Electrical wiring of the aforesaid building should be checked and maintenance to be done by a licenced electrician.
7. Mock practice and fire evacuation drills to be organised for the periodical performance in accordance to the National Building Code part IV
8. All Exit and entry should be free from obstruction

This certificate is valid for 3 years from the date of issue U/R 18 of WBFS (Fire Prevention And Safety) Rules 2018 (Amendment) and renewable after three years failing which will be revoked automatically.

Signature valid

Digitally Signed  
Name: DEWAN DEBCHANDRA  
Date: 01-Dec-2022 10:48  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Kalimpong  
Division, Kalimpong  
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192020/161867